

# Farmdale Water District

## Water Quality Report 2017

Water System ID: KY0370128  
Manager: David Robinson  
502-223-3562

CCR Contact: David Robinson  
502-223-3562  
farmdalewater@gmail.com

Mailing Address:  
100 Highwood Drive  
Frankfort, KY 40601

Meeting location and time:  
100 Highwood Drive  
First Friday at 8:00 AM

Frankfort Plant Board Water Treatment Plant treats surface water from pool #4 on the Kentucky River. Farmdale Water District purchases water from Frankfort. An analysis of the susceptibility of the water supply to contamination indicates that this susceptibility is generally moderate. Several highway bridges and major roads occur in the immediate vicinity of the intake. An accidental release of toxic materials from a nearby bridge or road could pose an immediate threat to Frankfort's intake. Other areas of concern that occur in the immediate vicinity of the intake include land used for agricultural purposes, firms that use Tier II hazardous chemicals, a Superfund site, a hazardous waste generator and/or transporter, sewer lines and a KPDES permitted discharger. Within the greater watershed area, there are numerous permitted operations and activities and other potential contaminant sources of moderate concern that cumulatively increase the potential for the release of contaminants within the area. These potential contaminant sources include everything from underground storage tanks, to power line rights-of-way that may be treated with herbicides, to active and inactive landfills. The Source Water Assessment Plan is available for inspection at the Frankfort Plant Board Water Treatment Plant.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects may be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and may pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include: Microbial contaminants, such as viruses and bacteria, (sewage plants, septic systems, livestock operations, or wildlife). Inorganic contaminants, such as salts and metals, (naturally occurring or from stormwater runoff, wastewater discharges, oil and gas production, mining, or farming). Pesticides and herbicides, (stormwater runoff, agriculture or residential uses). Organic chemical contaminants, including synthetic and volatile organic chemicals, (by-products of industrial processes and petroleum production, or from gas stations, stormwater runoff, or septic systems). Radioactive contaminants, (naturally occurring or from oil and gas production or mining activities). In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water to provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

### Information About Lead:

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Your local public water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

### Some or all of these definitions may be found in this report:

**Maximum Contaminant Level (MCL)** - the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal (MCLG)** - the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Maximum Residual Disinfectant Level (MRDL)** - the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG)** - the level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Below Detection Levels (BDL)** - laboratory analysis indicates that the contaminant is not present.

**Not Applicable (N/A)** - does not apply.

**Parts per million (ppm)** - or milligrams per liter, (mg/L). One part per million corresponds to one minute in two years or a single penny in \$10,000.  
**Parts per billion (ppb)** - or micrograms per liter, ( $\mu\text{g/L}$ ). One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

**Parts per trillion (ppt)** - one part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.

**Parts per quadrillion (ppq)** - one part per quadrillion corresponds to one minute in 2,000,000,000 years or one penny in \$10,000,000,000,000.

**Picocuries per liter (pCi/L)** - a measure of the radioactivity in water.

**Millirems per year (mrem/yr)** - measure of radiation absorbed by the body.

**Million Fibers per Liter (MFL)** - a measure of the presence of asbestos fibers that are longer than 10 micrometers.

**Nephelometric Turbidity Unit (NTU)** - a measure of the clarity of water. Turbidity has no health effects. However, turbidity can provide a medium for microbial growth. Turbidity is monitored because it is a good indicator of the effectiveness of the filtration system.

**Variations & Exemptions (V&E)** - State or EPA permission not to meet an MCL or a treatment technique under certain conditions.

**Action Level (AL)** - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system shall follow.

**Treatment Technique (TT)** - a required process intended to reduce the level of a contaminant in drinking water.

The data presented in this report are from the most recent testing done in accordance with administrative regulations in 401 KAR Chapter 8. As authorized and approved by EPA, the State has reduced monitoring requirements for certain contaminants to less often than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data in this table, though representative, may be more than one year old.

**Regulated Contaminant Testing Results for Farmdale Water District**

Contaminant [code] (units)	MCL	MCLG	Report Level	Range of Detection	Date of Sample	Violation	Likely Source of Contamination
<b>Inorganic Contaminants</b>							
Copper [1022] (ppm) sites exceeding action level 0	AL = 1.3	1.3	0.36 (90 <sup>th</sup> percentile)	0 to 0.67	Aug-17	No	Corrosion of household plumbing systems
Lead [1030] (ppb) sites exceeding action level 0	AL = 15	0	3 (90 <sup>th</sup> percentile)	0 to 10	Aug-17	No	Corrosion of household plumbing systems
<b>Disinfectants/Disinfection Byproducts and Precursors</b>							
Chloramines (ppm)	MRDL = 4	MRDLG = 4	2.66 (highest average)	2.2 to 2.9	2017	No	Water additive used to control microbes.
HAA (ppb) (Stage 2) [Haloacetic acids]	60	N/A	30 (high site average)	14 to 31 (range of individual sites)	2017	No	Byproduct of drinking water disinfection
TTHM (ppb) (Stage 2) [total trihalomethanes]	80	N/A	29 (high site average)	14.7 to 35 (range of individual sites)	2017	No	Byproduct of drinking water disinfection.

**Regulated Contaminant Testing Results for Frankfort Plant Board**

	Allowable Levels	Highest Single Measurement	Lowest Monthly %	Violation	Likely Source of Turbidity
Turbidity (NTU) TT * Representative samples of filtered water	No more than 1 NTU* Less than 0.3 NTU in 95% monthly samples	0.26	100	No	Soil runoff

**Regulated Contaminant Test Results**

Contaminant [code] (units)	MCL	MCLG	Report Level	Range of Detection	Date of Sample	Violation	Likely Source of Contamination
<b>Radioactive Contaminants</b>							
Combined radium (pCi/L)	5	0	2.66	2.66 to 2.66	Oct-17	No	Erosion of natural deposits
<b>Inorganic Contaminants</b>							
Barium [1010] (ppm)	2	2	0.023	0.023 to 0.023	Feb-17	No	Drilling wastes; metal refineries; erosion of natural deposits
Chromium [1020] (ppb)	100	100	0.3	0.3 to 0.3	Feb-17	No	Discharge from steel and pulp mills; erosion of natural deposits
Fluoride [1025] (ppm)	4	4	0.4	0.4 to 0.4	Feb-17	No	Water additive which promotes strong teeth
Nitrate [1040] (ppm)	10	10	0.6	0.3 to 0.6	Feb-17	No	Fertilizer runoff; leaching from septic tanks, sewage; erosion of natural deposits
<b>Disinfectants/Disinfection Byproducts and Precursors</b>							
Total Organic Carbon (ppm) (report level=lowest avg. range of monthly ratios)	TT*	N/A	1.43	1 to 2.67	2017	No	Naturally present in environment.

\*Monthly ratio is the % TOC removal achieved to the % TOC removal required. Annual average must be 1.00 or greater for compliance.

**Violation 2018-9458434**

We received a violation for failure to submit our Monthly Operating Report (MOR) to the Kentucky Division of Water by the tenth of the following month. This report includes daily testing results, chemicals added, and total volumes treated. We failed to submit an MOR for the period August 2017 by the tenth of September. There is nothing you need to do. We submitted the document to the Division of Water September 20, 2017.

**Spanish (Español) Este informe contiene información muy importante sobre la calidad de su agua beber. Tradúzcalo o hable con alguien que lo entienda bien.**

**Copies of this report are available at our office and will not be mailed unless requested.**